



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
RENEWAL of NO OBJECTION CERTIFICATE**



Ack. No:	134720002018
NOC:	0005211/RENEWAL/Medchal/2018
NOC TYPE:	RENEWAL*
Valid Upto:	05-08-2024
Applicant Details:	CH BHADRAREDDY,8008044111,Sy.No.59,Jayanagar Colony,New Bownpally,Secunderabad.
Building for which NOC issued:	M/s Chandramma Educational Society(Mallareddy Institute of Dental Scinces Hospital),Sy.No81,53,54,56,57,66,72,138,142&142, Suraram Village,Quthbullapur Mandal/- Jeedimetla/Qutubullapur/Medchal
Concessions in Setbacks Surrendered in Road Widening:	Given in Lieu of Land No
Plot Area (Sq. Mtrs):	9524.00
Height (Metres):	19.65
Open Spaces (Metres):	North: 12.80 South: 7.00 East: (F) 14.80 West: 12.80
No. of Floors:	0 Cellars, 0 Stilts, 1 Ground, 4 Floors, 0 Terrace
Total Built-up Area (Sq.Mtrs):	9523.76
Fees Paid (₹):	22500
Occupancy Type:	INSTITUTIONAL C-1 Hospitals, Sanatoria and Nursing Homes
Staircases:	No. of Staircases: 2 Required/Proposed: Aggregate Width: 6.00 (Metres):



Fighting Installations Provided as per Table 23, Part-IV of NBC, 2005:

Fire Extinguisher:	96	First Aid Hose Reel:	18	Wet Riser:	4
Down Comer:	0	Yard Hydrant:	10	Automatic Sprinkler System:	1039
Manually Operated Electronic Fire Alarm Systems:	18	Terrace Tank (Litres):	25000		
Automatic Detection and Alarm System:	688	Underground Static Water Storage Tank (Litres):	100000		

Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm2 at Terrace Level	Type	Quantity	(Capacity in Litres/min)
	Electrical	2	2280
	Diesel	1	2280
	Jockey	1	180

Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm2	(Capacity in Litres/min)
	900

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"
* For details and conditions of Renewal No Objection Certificate for Occupancy, refer overleaf.

B